WV-0018 #6

UNION CARBIDE INTERNAL CORRESPONDENCE

UNION CARBIDE CORPORATION TECHNICAL CENTER
P.O. BOX 8361, SOUTH CHARLESTON, WV 25303

To (Name) A. J. Bonham
Division 770-201
Location 511
Area

Copy to E. R. Hunter - 740/4111
C. P. Maxwell - 701/2
P. D. Sherman - 701/2

Date November 11, 1986

Originating Dept EM&TS - HS&EA

Area Industrial Hygiene

Subject Asbestos In Glass Blowing Shop

PLAINTIFF'S EXHIBIT UC-764

C. P. Maxwell received a request from Eugene Hunter to take a look at the material used for lining trays in the oven located in the glass blowing shop. A sample of this material was obtained by C. P. Maxwell that we analyzed for asbestos. The results show possible presence of chrysotile type asbestos material. The material in the oven is crumbling and presents a potential exposure problem.

I recommend that the material be carefully removed and replaced with a non-asbestos material. You may wish to consider a thermal barrier cloth such as Siltemp^{R} which offers protection up to 3000°F. If you are interested in this product, I have additional details available for your consideration.

Manhar A. Patel

Manhar A. Patel

MAP:rab
1882P

Union Carbide trial exhibit UC-764: Manhar A. Patel to A. J. Bonham on Asbestos in the Glass Blowing Shop Oven... Published by AsbestosClaims.Law
ACL Doc 15990 · Page 1 of 1 asbestosclaims.law/library/15990/1