WU-0018 #1

UNION CARBIDE INTERNAL CORRESPONDENCE

UNION CARBIDE CORPORATION TECHNICAL CENTER
P.O. BOX 8361, SOUTH CHARLESTON, WV 25303

PLAINTIFF'S EXHIBIT UC-768

To (Name) A. F. Terry
Division 704
Location 511
Area

Date June 25, 1987
Originating Dept. EM&TS - HS&EA
Area Industrial Hygiene

Copy to D. L. Brown - 704
C. P. Maxwell - 701/2
C. L. Ruddle - 704
R. E. Sergent - 704

Subject Asbestos Bulk Sample Analysis

Two samples you submitted for asbestos analysis showed the following results:

1. Material labeled Pipe Insulation - contained asbestos.

2. Material labeled Paper Pipe Insulation - did not contain asbestos.

These samples were collected from the Utility lines in the Laboratory located on the third floor of Building 701 undergoing renovation. The results were verbally communicated to you by V. E. Stover of our group.

Manhar A. Patel

Manhar A. Patel

MAP:rab
2425P