
10/30/90 17:05 ☎713 488 4661 NUS CORP. 001

PLAINTIFF'S EXHIBIT
UC-1925

Date: 10/30/90 Log Number: T853



NUS Laboratory Services

900 Gemini Avenue
Houston, Texas 77058
713-488-1810

800-262-3027 FAX 713-488-4661

TO: Belia Cortz

COMPANY: Union Carbide

TELECOPY NO.: (512) 831-5278

FROM: K Stewart

PAGE 1 OF 2 (Including Cover Page)

NUS CORPORATION

BRD 1395

Published by AsbestosClaims.Law
asbestosclaims.law/library/16984/1

Union Carbide C&P Co.
Brownsville, TX Plant
Asbestos Results

Sample ID	Result	Comments
108A	Negative	Cellulose fiber, Synthetic fiber
108B	Negative	Cellulose fiber, Synthetic fiber
108C	Negative	Mineral wool, Cellulose fiber
108D	Negative	Glass fiber
1 Bldg 124 - ceiling	Negative	Mineral wool, Cellulose fiber
200 Bldg 166 - pipe	Positive	2-5% Chrysotile, Cellulose fiber
201 Bldg 166 - pipe	Positive	35-45% Amosite, 10-20% Chrysotile
202 Bldg 166 - floor	Positive	Tile non-fibrous, matic contains 2-5% Chrysotile
203 Bldg 166 - Conduit	Positive	35-45% Amosite, 5-10% Chrysotile
204 Bldg 166 pipe	Positive	10-15% Amosite, 35-45% Chrysotile
205 #571 Insulation	Negative	Mineral wool, Cellulose fiber
206 #511 pipe	Positive	5-10% Chrysotile, 35-45% Amosite
207 #511 - floor	Positive	Tile non-fibrous, mastic contains 2-5% Chrysotile
208 Bldg 166 pipe outer west wall	Positive	30-40% Amosite
209 Bldg 166 - pipe back west	Positive	2-5% Chrysotile, 35-45% Amosite
210 Bldg 168 - pipe 1st Rm RH Side	Positive	5-10% Chrysotile, 35-45% Amosite

More results will be fax'd as available.

1/6 10 positive

BRD 1396