PLAINTIFF'S EXHIBIT

UC-2269

INDUSTRIAL HYGIENE - ENVIRONMENTAL PROTECTION

ENVIRONMENTAL HAZARD REPORT

DATE 4/7/77 TIME

PERSON REQUESTING ASSISTANCE Wilson Shelton

LOCATION 704 Shop DEPARTMENT Services

IH DEPARTMENT CONTACT Bill Blythe

REQUEST We were requested to monitor removal of insulation possibly containing asbestos at Bldg. 704 and behind Bldg. 778.

ACTION TAKEN Personal samples were taken on J. R. Monin while he removed the insulation. The insulation was wetted with water before and during removal and Mr. Monin wore a respirator. Concentrations of asbestos in air were 0.26 fibers/cc at the job in 704 at 0.06 fibers/cc at the job west of 778. These are well below the OSHA TLV of 2 fibers/cc.

IH FILE Asbestos 704, 778

(IH #1 2/77)

UCC 024250

Union Carbide trial exhibit UC-2269: Environmental Hazard Report on Monitoring Removal of Possible Asbestos Ins... Published by AsbestosClaims.Law
ACL Doc 17264 · Page 1 of 1 asbestosclaims.law/library/17264/1