PLAINTIFF'S EXHIBIT

UC-2272

UNION CARBIDE BUSINESS CONFIDENTIAL

INDUSTRIAL HYGIENE MONITORING FOR ASBESTOS

Computer Ref. W-1424
Date April 20, 1983

TO: H. R. Wright, 2000-107

cc: K.E. Denison, 2000-137
T.R. Damron, 2000-107
R.E. Peele, 701-334

PERSON MONITORED Area Sample

Location Bldg. 2000 - Photo Lab Date 04/07/83

EXPOSURE RESULTS

Sample No.	Conc.	Sampling Time	Comments
1	0.0 fibers/ cc	9 Hrs 31 Mins (0842-1813 hrs)	Sample collected on mixed cellulose ester filter
2			
3			
4			
5			
6			

Time-Weighted Average Concentration (TWA) -

Ceiling Concentration -

ALLOWABLE EXPOSURE

TWA	2 fibers/cc	X OSHA	___UCC	___Other
Ceiling		___OSHA	___UCC	___Other

COMMENTS

Air samples were collected in Millard Chambers' photo lab in response to his concern that particulate matter, which he had observed to settle on various surfaces throughout the lab, could possibly be asbestos fibers. An air sample designed to determine asbestos fiber concentration and a sample designed to determine total airborne dust concentration were collected. Sample analyses indicated that no asbestos fibers were present and that the dust level (0.008 mg/M^3) was below the ACGIH standard of 5 mg/M^3 for respirable dust. Please notify Mr. Chambers of sampling results.

WORK BY Mario F. Stowers
Mario F. Stowers

APPROVED BY Manhar A. Patel
Manhar A. Patel

UCC 024255

Union Carbide trial exhibit UC-2272: Industrial Hygiene Monitoring for Asbestos in Bldg. 2000 Photo Lab, M. F. Sto... Published by AsbestosClaims.Law
ACL Doc 17267 · Page 1 of 1 asbestosclaims.law/library/17267/1