UNION CARBIDE

INTERNAL CORRESPONDENCE

IN FILE COPY

PLAINTIFF'S EXHIBIT

UC-2282

UNION CARBIDE CORPORATION TECHNICAL CENTER

P.O. BOX 8361, SOUTH CHARLESTON, WV 25303

To (Name) L. A. Kapicak
Division 770-240
Location 511
Area

Date October 29, 1986

Originating Dept EM&TS - HS&EA

Area Industrial Hygiene

Copy to C. P. Maxwell - 701/256
R. E. Sergent - 704/2
P. D. Sherman - 701/254
P. H. Wadia - 770/304

Subject Asbestos Area Monitoring

Attached are the monitoring results of the Asbestos Area samples collected in 770-137 on October 23, 1986. The samples were collected to determine the level of airborne fibers present in this lab. Insulators had cleaned, from the floor area, Asbestos containing materials the evening of October 22, 1986.

The samples when counted did not show fiber count any greater then the blank samples and therefore, the results are well below the 0.1 fiber/cc action level, established by OSHA for an 8-hour workday.

If we can be of further assistance, please call us on extension 4779 or 3750.

WORK BY:

Vance E. Stover

APPROVED BY:

Manhar A. Patel

Attachment

VES:MAP:rab
1837P

UCC 024280

ASBESTOS AREA MONITORING

Comp. Ref. W2069

Date	Sampling Time	Air Conc. fibers/cc	COMMENTS
10-23-86	7 hrs 28 min.	$\angle$ 0.003	Collected at the face of the hood behind J. Winkler's desk and very near the point where the Asbestos was lying on the floor.
10-23-86	7 hrs 29 min.	$<$ 0.003	Collected on top of J. Winkler's desk.
10-23-86	7 hrs 24 min.	$<$ 0.003	Collected near the double doors that enter the hallway.

ASBESTOS

Permissible Exposure Level		
TWA_8	0.2 fiber/cc	OSHA
Action Level	0.1 fiber/cc	

1837P

Union Carbide trial exhibit UC-2282: V. E. Stover and M. A. Patel to L. A. Kapicak on Asbestos Area Monitoring in L… Published by AsbestosClaims.Law
ACL Doc 17274 · Page 2 of 2 asbestosclaims.law/library/17274/2