PLAINTIFF'S EXHIBIT

UC-2934

INDUSTRIAL HYGIENE RESULTS

DATE: March 25, 1983.

PROJECT: Sample and identify insulation on T-1098, water tank, near the tower in the Esters area; the protective cover has fallen off part of the insulation.

DATE OF SAMPLES: 3-23-83

SUMMARY:

DATE	SAMPLE FROM	IDENTITY
3-23-83	Shredded, loose insulation, T-1098	No asbestos noted
3-23-83	Rigid insulation, T-1098	No asbestos noted

RECOMMENDATIONS: Share this information with Esters area personnel.

DISCUSSION: Part of the cover has fallen off the insulation on T-1098 located near the S-W corner of the Esters tower. We noticed the strong wind on 3-23-83 was blowing the loose insulation on to the concrete pad. Thinking it might contain asbestos, we sampled it for identification.

METHOD OF ANALYSIS: Chemical Microscopy

DATA AND REPORT BY: H. G. Kuntz/K. E. Williams

ANALYSIS BY: V. H. McCool

COPY TO: D. G. Beddow, M. W. Bosserman, A. A. Cosper,Jr., K. A. Hickman, J. B. Mickey, A. G. Olds, R. L. Pitrolo, F. M. Plechaty.

K. E. Williams

UCC 016212

Union Carbide trial exhibit UC-2934: Industrial Hygiene Results: Insulation Sampling on Water Tank T-1098, Esters... Published by AsbestosClaims.Law
ACL Doc 17788 · Page 1 of 1 asbestosclaims.law/library/17788/1