WU-0105 #1

PLAINTIFF'S EXHIBIT

UC-3114

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	3-11-87	Albert Tenny	791-Basement Boiler Room Tank Area	-	+	JES	Samples Analyzed Contain Amosite and/or Crocidolite Type Asbestos
2	3-11-87	1114 Parker	Block-odorous	-	+	JES	

UCC 019388

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	2-10-87	M. Kingrey	706 & 707 Light Fixtures	+	Inconclusive treat as +	UES	Contains Chrysotile type Asbestos and maybe Crocidolite and/or Amosite

Copy to:

M Kingrey 704/
M A Patel 701

UCC 019389

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulation...
ACL Doc 17953 · Page 2 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/2

K .762

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	2-9-87	C.P. Maxwell QW. Decker	7410 Library	—	—	CES	Advised Q. Decker of results on 2-9-87

Copy to: CP Maxwell
QW Decker

UCC 019390

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulation...
ACL Doc 17953 · Page 3 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/3

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	2-4-87	MAP & VES	Bldg 3005 Steel Beam behind Ceiling - Collected above Conference Room 1B	Inconclusive Probably -	+	VES	Turned dark red immediately - Treat as Asbestos

UCC 019391

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulation...
ACL Doc 17953 · Page 4 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/4

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulation...
ACL Doc 17953 · Page 5 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
#1	1-2-87	Al Terry	Bldg 2000 Absorbers	—	+	VES	All samples may contain type I Asbestos amosite or crocidolite
#2	1-2-87	Al Terry	Bldg 2000 Absorbers	—	+	VES	Fe coloring was very light orange-red
#3	1-2-87	Al Terry	Bldg 2000 Absorbers	—	+	VES	

UCC 019392

Copy To: Pete Ruddle
Albert Terry
M. Patel

Vana:

Did you verbally communicate results to Al Terry. He may not be able to interpret results of samples 2 and 3 [illegible]

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/5

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	11-26-86	Mike Alsop	Gloves	+	+	JES	May contain chrysotile amosite and/or crocidolite type Asbestos - Tried to ID form @ 1535 11-26-86 but Alsop on Vacation

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulation… Published by AsbestosClaims.Law
ACL Doc 17953 · Page 6 of 34 **asbestosclaims.law/library/17953/6**

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulation...
ACL Doc 17953 · Page 7 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	11-10-86	C.P. Maxwell	Glass Shop-oven	+	—	JES	Chrysotile type Asbestos may be present.
2	11-10-86	J.R. Bailey	770-133 500° Muffle Furnace - Been on heater for approx 1 year 12-85	—	—	JES	

UCC 019394

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/7

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	11-7-86	D. Kerns 770-Shop	EO Autoclave Heater	+	+	JES	may contain amosite, Crocidolite and/or Chrysotile type Asbestos

UCC 019395

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulation...
ACL Doc 17953 · Page 8 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/8

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulation...
ACL Doc 17953 · Page 9 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	10-22-86	Jane (W.) Nkl on	770-137 Floor	—	+	UES	Amosite and/or Crocidolite Asbestos may be present

UCC 019396

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/9

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 10 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
701-B24	10-16-86	Ralph Hess	701-B24	–	+	JES	May contain amosite or crocidolite asbestos
	10-16-86	Albert Ferry		–	+	JES	"

UCC 019397

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/10

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 11 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	9-25-86	UES per CPM	705 cell 3	−	+	UES	may contain amosite or crocidilite type Asbestos
2	9-25-86	UES	705-cell 2 Asbestos Tape wrap	−	+	UES	Same as #1
3	9-25-86	UES per JDMcCue	705 - East steam leak in front of cell 1	+	+	UES	may contain amosite, crocidilite and or chrysotile type Asbestos
4	9-25-86	UES per JDMcCue	705 - Hot water in front of cell 12	+	+	UES	Same as #3
Tape 2	9-25-86	Theresa Fortin		−	−	UES	NO Asbestos present (Dark colored tape)
Tape 1	9-25-86	Theresa Fortin		+	−		may contain chrysotile type Asbestos

UCC 019398

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/11

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 12 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	8/27/86	Freddy Creech	726 Steamline Office Area	–	+	CES	May contain Amosite or Crocidolite type Asbestos - Treat as Asbestos Informed A. Terry and gave him a copy of this sheet CES

UCC 019399

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/12

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 13 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	8-20-74	J.R. McGee	Mechanical Shop 740-1128	—	—	CES	Not Asbestos

UCC 019400

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/13

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 14 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	6-23-86	Walt Filipek	Transite building 400 Sandblast Shed NE Corner So. Chas.	−	+	JES	To be treated as Asbestos

UCC 019401

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/14

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 15 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
720-1	5-30-86	M.A. Patel / R. Brabbin	720-pyrobar Block	+	+	JES	Unwrapped sample - ~~Treat as asbestos~~ - Gypsum
720-2	5-30-86	M.A. Patel / R. Brabbin	720-wall Plaster	+	—	JES	wrapped sample - ~~Treat as asbestos~~ - Fiberglas

Both Samples were analyzed by Electron Microscopy
Both were Not Asbestos

UCC 019402

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/15

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 16 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
720-1	5-30-86	M.A. Patel / R. Brabbin	720-pyrobar Block	+	+	JES	Unwrapped sample - Treat as asbestos
720-2	5-30-86	M.A. Patel / R. Brabbin	720-wall Plaster	+	—	JES	wrapped sample - Treat as asbestos

UCC 019403

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/16

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 17 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
701-B-EF	4-22-86	J.D. McCue	701 Basement in front of Elevator	—	+	JES	
701-B-50# steam line	4-22-86	J.D. McCue	701-Basement in center aisle near elevator - 50# Steam line	—	+	JES	Very Dark Red
701-B-200# steam line	4-22-86	J.D. McCue	701 Basement in center aisle near elevator 200# Steam line	—	+	JES	

UCC 019404

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/17

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 18 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	4-2-86	JE Stan	791 - East End over Doorway	—	+	JES	The Iron results were ~~between~~ Orange-red. Treat as asbestos.

UCC 019405

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/18

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	2-12-86	Albert Terry	Bldg 773	−	+	JES	Notified A Terry of positive Iron test and to be treated as "bestos.

UCC 019406

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 19 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/19

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 20 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	10/4/85	M. Patel	Institute	—	+	UES	Positive Fe Test - Probably Contains Asbestos
	10-21-85	F. Sunderland	Institute				Called about stripping 50' of Asbestos from 1½" Line.

UCC 019407

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/20

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 21 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results		Analyzed By	Remarks
				Mg Test	Fe Test		
1	6-28-85	L.R. Noble	Bldg. 727 roof	Negative	Negative	MFS	Sample burned w/ Propane torch and was found to melt; not asbestos

UCC 019408

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/21

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	6-28-85	W.T. Shelton	Water Tank @ Timberland	Negative	Negative	MFS	Sample also burned w/ propane torch; was found to melt; definitely not asbestos

UCC 019409

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 23 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1.	5-8-85	W.T. Shelton	Bldg. 707; Cell 4 outside ground level	Negative *	Negative	MFS	* Sample is not asbestos
2.	"	W.T. Shelton	Bldg. 2000; Basement services Rm.	Negative	Positive	MFS	Sample probably contains asbestos; should be treated as such

* Note - retested sample on 5-10-85 and obtained positive result for Fe test; Sample should be treated as asbestos MFS

UCC 019410

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/23

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 24 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1.	4-29-85	W.T. Shelton	Bldg 773 - 1st level	Negative	Positive	MFS	Sample Probal Contains asbes
2.	"	"	Bldg 773 - 3rd level	Negative	Positive	MFS	Sample Probal Contains asbest
3.	"	"	Bldg. 773 - Reactor ; North East Corner	Negative	Negative	MFS	Sample is n. asbestos
4.	"	"	Bldg. 773 - Reactor ; North East Corner	Negative	Negative	MFS	Sample is not asbestos

UCC 019411

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/24

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	4-25-85	Gene Moss	Bldg. 707 2nd level Operating Area	Negative	Positive	MFS	Sample could possibly contain asbestos

UCC 019412

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 25 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/25

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	4-1-85	Dennis Raines - Institute Plant	Insulation Fab. Shop.	Neg.	Pos.	MFS	Fe test indicates possibility that material could contain asbesto.

UCC 019413

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 26 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/26

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 27 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
#1	3-26-85	L.A. Monday	Ceiling Tile - Bldg. 770-1	Negative	Negative	MFS	Sample doesn't contain asbest.
#2	3-26-85	L.A. Monday	Ceiling Tile - Bldg. 770-2	Positive	-	MFS	Fe test not run since Mg test is pos.- Could contain Asbest
#3	3-26-85	L.A. Monday	Ceiling Tile - Bldg. 770-3	Negative	Negative	MFS	Sample doesn't Contain asbestos
#4	3-26-85	L.A. Monday	Ceiling Tile - Bldg. 773-4	Positive	-	MFS	Fe test not run since Mg test i pos. - Sample co contain asbestos
#5	3-26-85	L.A. Monday	Ceiling Tile - Bldg. 781-5	Positive	-	MFS	Fe test not ru since Mg Test is pos.- Sample could contain asbestos

UCC 019414

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/27

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 28 of 34

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	3-15-85	John Webb Larry Banas	Coating on vessel from Texas City @ Inst. Plant	Negative	Negative	M.F. Stowers	Sample does not appear to contain asbestos

UCC 019415

Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/28

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	1-29-15	Fred Ferrell	Ceiling tile from Bldg. 740 office	Negative	Negative	M.F. Stowers	

UCC 019416

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 29 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/29

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	11-3-84	H. Barringer	Gasket	Negative	Positive	M.F. Stowers	

UCC 019417

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 30 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/30

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	11-8-84	Jim Campbell	Store Room	Positive	—	M.F. Stowers	Fe test not run since Mg test positive

UCC 019418

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 31 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/31

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	10-16-84	W.L. Bare	SID; Gasket material on Analyzer Oven	Positive	-	M.F. Stowers	Fe test not run since Mg is positive.

UCC 019419

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 32 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/32

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	10-3-84	Ronnie Raines (Insulator)	Steam line on 3rd floor of powerhouse	Negative	Positive	M.F. Stowers	

UCC 019420

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 33 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/33

INSULATION ASBESTEST RESULTS FORM

Sample No.	Date	Sample Submitted By	Sample Source	Results Mg Test	Results Fe Test	Analyzed By	Remarks
1	10-2-84	J. R. Moss	SID	Positive	—	M.F. Stowers	Fe test not run since Mg test positive
2	10-2-84	J. R. Moss	SID	Positive	—	M.F. Stowers	Fe test not run since Mg test positive
3	10-2-84	J. R. Moss	SID	Positive	—	M.F. Stowers	Fe test not run since Mg test positive

UCC 019421

Union Carbide trial exhibit UC-3114: Insulation Asbestest Results Forms Logging Asbestos Spot Tests on Insulatio...
ACL Doc 17953 · Page 34 of 34
Published by AsbestosClaims.Law
asbestosclaims.law/library/17953/34