PLAINTIFF'S EXHIBIT

UC-3373

ATI ASBESTOS TESTING INC.
5205 NOYES AVE. • CHARLESTON, WV 25304 • (304) 925-6795

November 18, 1986

Erik A. Osby
Industrial Hygiene Dept.
Union Carbide Corporation
P.O. Box 2831
Charleston, WV 25330

The following bulk insulation analysis pertain to samples received on 11/14/86. All bulk insulation analyses are performed in accordance with EPA recommendations concerning analysis of bulk insulation using Polarized Light Microscopy.

ANALYSIS RESULTS

Sample #1	
Roofing material-Bldg. 190	70%-Asbestos (Chrysotile) 30%-Epoxy Resin
Sample #2	
Ceiling material, womens' bathroom-Bldg. 190	N.D.-Asbestos* 5%-Cellulose 95%-Gunnite Clay
Sample #3	
Material deposited on compressor-Bldg. 190 11/13/86	N.D.-Asbestos* 5%-Mineral Wool 5%-Synthetics Fibers 35%-Dirt 55%-Paint
Sample #4	
Ten inch pipe insulation (mid-section)- Bldg. 308	15%-Asbestos (Chrysotile) 85%-Clay
Sample #5	
Verticle steamline insulation from hallway in mid-section of Bldg. 308	35%-Asbestos (Chrysotile) 65%-Clay

Respectfully submitted,

A03986

John S. Ferrell
Industrial Hygienist

*N.D. denotes none detected.

UCC 008963